

CERTIFICATE No. 50/18/Z of Conformity to European Directive

Certification program acronym – PDCWPA

Name and address of the certificate owner: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Name and address of the manufacturer: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Place of production: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Product: Emergency lighting fitting INFINITY II
220-240V, 50/60Hz, kl. II, IP44, LED 3W according to enclosure

The product meet requirements of the Low Voltage Directive 2014/35/UE


Assessment of conformity was conducted on the basis of:

- Testing in scope of the harmonized standards: **PN-EN 60598-1:2015-04+AC:2016-02 (IDT EN 60598-1:2015/AC:2016)**, **PN-EN 60598-2-22:2015-01+AC1:2015-10+AC:2016-07+AC:2016-11 (IDT EN 60598-2-22:2014/AC:2015/AC:2016-05/AC:2016-09)**, **PN-EN 60598-2-22:2015-0+AC1:2015-10+AC:2016-07+AC:2016-11 (IDT EN 60598-2-22:2014/AC:2015/AC:2016-05/AC:2016-09)** according to the Testing Reports No B/2018/28/3/1-8 of 28.03.2018, nr B/2018/28/4/1-8 of 27.04.2018 conducted by the Accredited Laboratory.
- Results of the inspection of organizational technical conditions conducted by accredited authorized and notified body for certification - according to the Report No 137/2016 of 27.12.2016.

This Certificate which is a revision to the Certificate issued for the first time on 29.03.2015 is valid until
28.03.2023

The right to use the Certificate refers exclusively to products with identical properties (parameters) to the tested model and which meets requirements mentioned above.

DYREKTOR DS. CERTYFIKACJI


dr inż. Tomasz Włodek



PREZES ZARZĄDU


mgr inż. Edward Makieła

Katowice, 17.05.2018

**Enclosure
to the Certificate No. 50/18/Z
of 17.05.2018**

List of new variants of INFINITY II light fittings:

CODE OF LIGHTING FITTING	POWER OF LIGHTING FITTING	CODE OF EMERGENCY MODULE	TIME OF WORK IN EMERGENCY MODE [h]	TYPE OF WORK	TYPE OF TESTING OF LIGHTING FITTING	COLOUR SYMBOL OF THE LIGHTING FITTING
IF2AWS IF2AWD IF2ACS IF2ACD IF2ALS IF2ALD IF2BWS IF2BWD	1W 2W 3W	A B C E*	1 2 3	SE SA	X	GR WH BL OC GX WX BX OX
		A B C E*	1 2 3	SE SA	PT	
		A B C E*	1 2 3	SE SA	AT	
		A B	1 2 3	SE SA	RS RU RW	
		F G Z**	-	-	CB CB/CBS CB/ADE CB/ADP	
		-	-	-	FZLV	

Marking of modules:

A - Uniled

B – Uniled BM

C – Uniled BMA

E – Uniled NC

F – Uniled CB

G – Uniled CB-H

Z** – supply system integrated with address module (marking applies only for modules ADP, ADE)

ADP – address module ADP

ADE – address module ADE

SE – emergency (dark)

SA – mains-emergency (bright)

AT – autotest

PT – test button

RS – Rubic system

RU – Rubic system

RW – Rubic system

CB – central battery

CBS – central battery (Awex)

IF2AWS – lighting fitting Infinity II double-sided mural standard

IF2AWD – lighting fitting Infinity II double-sided mural with additional illumination

IF2ACS – lighting fitting Infinity II double-sided ceiling standard

IF2ACD – lighting fitting Infinity II double-sided ceiling with additional illumination

IF2ALS – lighting fitting Infinity II double-sided hanging standard

IF2ALD – lighting fitting Infinity II double-sided hanging with additional illumination

IF2BWS – lighting fitting Infinity II one-sided standard

IF2BWD – lighting fitting Infinity II one-sided with additional illumination

GR – grey color, version z IP40

WH – white color, version z IP40

BL – black color, version IP40

OC – other colors, version z IP40

GX – grey color, version z IP44

WX – white color, version z IP44

BX – black color, version IP44

OX – other colors, version z IP44

1W, 2W, 3W – power of light source

* - only SE work (emergency)

DYREKTOR DS. CERTYFIKACJI



dr inż. Tomasz Włodek



PREZES ZARZĄDU



mgr inż. Edward Makiela