

CERTIFICATE No. 112/18/Z of Conformity to European Directive

Certification program acronym – PDCWPA

Name and address of the certificate owner: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Name and address of the manufacturer: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Place of production: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Product: Emergency lighting fitting SK-8
220-240V, 50-60Hz, kl. II, IP44, LED lub 24V DC, kl. III, IP44, LED
according to enclosur

The product meet requirements of the Low Voltage Directive 2014/35/UE


Assessment of conformity was conducted on the basis of:

- Testing in scope of the harmonized standards:
PN-EN 60598-1:2015-04+AC:2016-02 (IDT EN 60598-1:2015/AC:2016),
PN-EN 60598-2-22:2015-01+AC1:2015-10+AC:2016-07+AC:2016-11
(IDT EN 60598-2-22:2014/AC:2015/AC:2016-05/AC:2016-09) according to the Testing Reports
No B/2018/258/1-8 of 30.08.2018 conducted by the Accredited Laboratory.
- Results of the inspection of organizational technical conditions conducted by accredited authorized and notified body for certification - according to the Report No 76/2018 of 03.07.2018.

The right to use the certificate includes the period from 28.09.2018 to 27.09.2023

and refers exclusively to products with identical properties (parameters) to the tested model and which meet requirements mentioned above.

DYREKTOR DS. CERTYFIKACJI



dr inż. Tomasz Włodek



PREZES ZARZĄDU



mgr inż. Edward Makiela

Katowice, 28.09.2018

Enclosure
to the Certificate No. 112/18/Z
of 28.09.2018

List of new variants of SK-8 light fittings:

CODE OF LIGHTING FITTING	POWER OF LIGHTING FITTING	CODE OF EMERGENCY MODULE	TIME OF WORK IN EMERGENCY MODE [h]	TYPE OF WORK	TYPE OF TESTING OF LIGHTING FITTING	COLOUR SYMBOL OF THE LIGHTING FITTING
SK8	1W 1,2W 2W 3W 3,2W	B C E	1 2 3	SE	X	WT WL GT GL OT OL
	1W 1,2W 2W 3W 3,2W	B C	1 2 3	SA	X	
	1W 1,2W 2W 3W 3,2W	B C E	1 2 3	SE	PT	
	1W 1,2W 2W 3W 3,2W	B C	1 2 3	SA	PT	
	1W 1,2W 2W 3W 3,2W	B C E**	1 2 3	SE SA	AT	
	1W 1,2W 2W 3W 3,2W	B	1 2 3	SE SA	RS RU RW	
	1W 1,2W 2W 3W 3,2W	F G Z*	-	-	CB CB/CBS CB/ADS CB/ADL CB/ADP CB/ADE	
	1W 1,2W 2W 3W 3,2W	-	-	-	FZLV	

Marking of modules:

B – Uniled BM

C – Uniled BMA

E – Uniled NC

F – Uniled CB

G – Uniled CB-H

ADS – address module ADS20

ADL – address module ADL20

ADP – address module with power supply

ADE – address module with power supply

SE – emergency (dark)

SA – mains-emergency (bright)

X – testing by plugging testing device

AT – autotest

PT – test button

RS – Rubic system

RU – Rubic system

RW – Rubic system

CB – central battery

CBS – central battery (Awex)

FZLV – central battery 24V

SK8 – lighting fitting SK-8

WT – white lighting fitting with transparent shade

WL- white lighting fitting with milky shade

GT – gray lighting fitting with transparent shade

GL - gray lighting fitting with milky shade

OT – other colors with transparent shade

OL – other colors with milky shade

1W;1,2W;2W;3W;3,2W – power of light source

* - marking Z applies only for modules ADP, ADE

** - only SE work (emergency)

DYREKTOR DS. CERTYFIKACJI

dr inż. Tomasz Włodek



PREZES ZARZĄDU

mgr inż. Edward Makiela