



CERTIFICATION BODY



AC 005

CERTIFICATE No. 44/12

of conformity to European Directive

Product certification system - 5 acc. PKN-ISO/IEC Guide 67:2007
Certification program acronym - PDCWEEIM

Name and address of the certificate owner: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Name and address of the manufacturer: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Place of production: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Product: Maintained and maintained emergency fitting group type ESCAPE LED
according to enclosure
230V, 50Hz, kl. I, IP20, LED 1,2W

The product meet requirements of the Low Voltage Directive 2006/95/WE.

Assessment of conformity was conducted on the basis of:

- Testing in scope of the harmonized standards:
PN-EN 60598-1:2011 IDT EN 60598-1:2008/A11:2009, PN-EN 60598-2-22:2004+A2:2010 IDT EN 60598-2-22:1998/A2:2008 according to the Testing Reports No B/2012/101 of 23.04.2012 conducted by the Accredited Laboratory.
- Results of the inspection of organizational technical conditions conducted by accredited authorized and notified body for certification - according to the Report No 54/2011 of 21.07.2011.

The right to use the certificate includes the period from 26.04.2012 to 25.04.2015

and refers exclusively to products with identical properties (parameters) to the tested model and which meet requirements mentioned above.

DYREKTOR ds. CERTYFIKACJI

mgr inż. Ewa Suchan



PREZES ZARZĄDU

mgr inż. Edward Makiela

Katowice, 26.04.2012

Series of types of lighting fittings ESCAPE LED

EL/1/SE, EL/2/SE, EL/3/SE,
EL/1/SA, EL/2/SA, EL/3/SA,
EL/1/SE/PT, EL/2/SE/PT, EL/3/SE/PT,
EL/1/SA/PT, EL/2/SA/PT, EL/3/SA/PT,
EL/1/SE/AT, EL/2/SE/AT, EL/3/SE/AT,
EL/1/SA/AT, EL/2/SA/AT, EL/3/SA/AT,
EL/1/SE/RS, EL/2/SE/RS, EL/3/SE/RS,
EL/1/SA/RS, EL/2/SA/RS, EL/3/SA/RS,
EL/CB
EL/S

Legend:


SE – emergency (dark)
SA – emergency-mains (bright)
PT – manual test button
RS – monitoring system RUBIC
AT – autotest
S – mains
CB – for central battery EVG AC/DC
EL – lighting fitting ESCAPE LED

DYREKTOR ds. CERTYFIKACJI


mgr inż. Ewa Suchan



PREZES ZARZĄDU


mgr inż. Edward Makiela