



Ref. Certif. No.

GB919W Issue 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product
Produit

Emergency Luminaires

Name and address of the applicant
Nom et adresse du demandeurAwex Spółka z o.o. Spółka komandytowa
Masłomiaça, Długa 39
32-091 MICHAŁOWICE
PolandName and address of the manufacturer
Nom et adresse du fabricant

As above

Name and address of the factory
Nom et adresse de l'usine

As above

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principalesInput 220-240V AC 50/60 Hz Class II or 24 VDC Class III, Infinity IP40 &
SK8 IP44Trademark (if any)
Marque de fabrique (si elle existe)

AWEX

Model / Type Ref.
Ref. De type

See pages 2 & 3

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent
être indiqués sur la 2^{ème} page

See page 2

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

PUBLICATION	EDITION
IEC 60598-1:2008	7 th
IEC 60598-2-22:1997+A2:2008	3 rd

As shown in the Test Report Ref. No. which forms part of
this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

Report number: TR/15/103 Issue 2 (8207387)

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Date: 05 September 2016

Original Issue Date 4 September 2015

Signature:

Mark Littlejohns Certification Manager



Ref. Certif. No.

GB919W Issue 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

The type references covered by this certificate are as listed below:

Model ref.	Power	Light source/ emergency module code	Duration	Mode	Option	Cover code or colour	Assembly type
------------	-------	--	----------	------	--------	-------------------------	------------------

Self-contained

INFINITY A IFAC/IFAR/IF AD/IFAS	1W 2W 3W	LED/ B	1/2/3 Hrs	Non-maintained (SE) Maintained (SA)	X/PT/AT/RU	WH/GR/BL	Ceiling surface/ suspension/ recessed. Exit sign
INFINITY B IFB	1W 2W 3W	LED / B	1/2/3 hrs	Non-maintained (SE) Maintained (SA)	X/PT/AT/RU	WH/GR/BL	Wall surface/ recessed. Exit sign
SK8 SK8	1W 2W 3W	LED / B	1/2/3 Hrs	Non-maintained (SE) Maintained (SA)	X/PT/AT/RU	WT/WL/GT/ GL	Ceiling/Wall. Exit sign

Central Battery

INFINITY A IFAC/IFAR/IF AD/IFAS	1W 2W 3W	LED/ F / Z	Dependent on Power system	Central battery (CB)	CBS/ADS/ ADP	WH/GR/BL	Ceiling surface/ suspension/ recessed. Exit sign
INFINITY B IFB	1W 2W 3W	LED / F / Z	Dependent on Power system	Central battery (CB)	CBS/ADS/ ADP	WH/GR/BL	Wall surface/ recessed. Exit sign
SK8 SK8	1W 2W 3W	LED / F / Z	Dependent on Power system	Central battery (CB)	CBS/ADS/ ADP	WT/WL/GT/ GL	Ceiling/Wall. Exit sign

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification****bsi.**BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Date: 05 September 2016

Original Issue Date 4 September 2015

Signature: 

Mark Littlejohns Certification Manager



Ref. Certif. No.

GB919W Issue 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

The type references covered by this certificate are as listed below

Model ref.	Power	Light source	Duration	Mode	Option	Cover code or colour	Assembly type
FZLV - Central Power System							
INFINITY A IFAC/IFAR/IFAD/IFAS	1W 2W 3W	LED	Dependent on Power system	Central Power System (FZLV)	NA	WH/GR/BL	Ceiling surface/ suspension/ recessed. Exit sign
INFINITY B IFB	1W 2W 3W	LED	Dependent on Power system	Central Power System (FZLV)	NA	WH/GR/BL	Wall surface/ recessed. Exit sign
SK8 SK8	1W 2W 3W	LED	Dependent on Power system	Central Power System (FZLV)	NA	WT/WL/GT/ GL	Ceiling/Wall. Exit sign

Ledgend

IFAC – fixture Infinity IFAC	SK – fixture Infinity SK8
IFAS – fixture Infinity IFAS	AT – autotest
IFAD – fixture Infinity IFAD	PT – test button
IFAR – fixture Infinity IFAR	RU – rubic system UNA
IFB – fixture Infinity IFB	NA – not applicable
ADS – central battery with address module ADS20	ADP – central battery with electronic control gear Uniled ADP
CBS – central battery system	WL – white body with opal cover
WT – white body and transparent cover	GL – grey body and opal cover
GT – grey body and transparent cover	WH – fixture is White, GR – fixture is Gray, BL - fixture is Black

Also tested to the requirements of:

BS EN 60598-1:2008 + A11:2009, BS EN 60598-2-22:1998+A2:2008,
EN 60598-1:2008 + A11:2009 & EN 60598-2-22:1998+A2:2008.

Including European & Group differences.

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Date: 05 September 2016

Original Issue Date 4 September 2015

Signature:

Mark Littlejohns Certification Manager