



Ref. Certif. No.

GB920W Issue 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product
Produit

Emergency Luminaires

Name and address of the applicant
Nom et adresse du demandeurAwex Spółka z o.o. Spółka komandytowa
Masłomiaça, Długa 39
32-091 MICHAŁOWICE
PolandName and address of the manufacturer
Nom et adresse du fabricant

As above

Name and address of the factory
Nom et adresse de l'usine

As above

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Input 220-240V AC 50/60 Hz Class I or 24 VDC Class III, SCREEN IP40

Trademark (if any)
Marque de fabrique (si elle existe)

AWEX

Model / Type Ref.
Ref. De type

See page 2 and 3

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent
être indiqués sur la 2^{ème} page

See page 2

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

PUBLICATION	EDITION
IEC 60598-1:2008	7 th
IEC 60598-2-22:1997+A2:2008	3 rd

As shown in the Test Report Ref. No. which forms part of
this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

Report number: TR/15/104 Issue 2 (8207387)

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000Date: 06 September 2016
Original Issue date 04 September 2015

Signature:

Mark Littlejohns Certification Manager

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

The type references covered by this certificate are as listed below:

Model ref.	Power	Light source/ emergency module code	Duration	Mode	Option	Cover code or colour	Assembly type
------------	-------	---	----------	------	--------	----------------------------	------------------

Self-contained

SCREEN SC30 SC40 SC60	3x1W 3W 2x3W	LED / B	1/2/3 Hrs	Non-maintained (SE) Maintained (SA)	X/PT/AT/RU	GR	Wall surface Exit sign
SCREEN DS SCS30 SCS40 SCS60	3x1W 3W 2x3W	LED / B	1/2/3 Hrs	Non-maintained (SE) Maintained (SA)	X/PT/AT/RU	GR	Ceiling Exit sign

Central Battery

SCREEN SC30 SC40 SC60	3x1W 3W 2x3W	LED / F / Z	Dependent on Power System	Central Battery (CB)	CBS/ADS/ ADP	GR	Wall surface Exit sign
SCREEN DS SCS30 SCS40 SCS60	3x1W 3W 2x3W	LED / F / Z	Dependent on Power System	Central Battery (CB)	CBS/ADS/ ADP	GR	Ceiling Exit sign



BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Date: 06 September 2016
Original Issue date 04 September 2015

Signature:



Mark Littlejohns Certification Manager

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
 CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
 CB SCHEME

 SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
 D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
 METHODE OC

CB TEST CERTIFICATE
CERTIFICAT D'ESSAI OC

The type references covered by this certificate are as listed below:

Model ref.	Power	Light source	Duration	Mode	Option	Cover code or colour	Assembly type
------------	-------	--------------	----------	------	--------	----------------------	---------------

FZLV Central Power system

SCREEN SC30 SC40 SC60	3x1W 3W 2x3W	LED	Dependent on Power system	Central Power System (FZLV)	NA	GR	Wall surface Exit sign
SCREEN DS SCS30 SCS40 SCS60	3x1W 3W 2x3W	LED	Dependent on Power system	Central Power System (FZLV)	NA	GR	Ceiling Exit sign

Legend

SC30 – fixture SCREEN viewing distance 30m	SCS30 – fixture SCREEN DS viewing distance 30m
SC40 – fixture SCREEN viewing distance 40m	SCS40 – fixture SCREEN DS viewing distance 40m
SC60 – fixture SCREEN viewing distance 60m	SCS60 – fixture SCREEN DS viewing distance 60m
AT – autotest	PT – test button
NA – not applicable	RU – rubic system UNA
B – code of emergency module (Uniled BM)	Z – code of emergency module (Uniled ADP)
F – code of emergency module (Uniled HDP)	X – without option
ADS – central battery with address module ADS20	CBS – central battery system
ADP – central battery with electronic control gear Uniled ADP	GR – Grey

Also tested to the requirements of:

BS EN 60598-1:2008 + A11:2009, BS EN 60598-2-22:1998+A2:2008.

Including European & Group differences.

 This CB Test Certificate is issued by the National Certification Body
 Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**


 BSI, Kitemark Court,
 Davy Avenue, Milton Keynes,
 MK5 8PP. United Kingdom.
 Phone +44 (0)8450 809000

 Date: 06 September 2016
 Original Issue date 04 September 2015

Signature:



Mark Littlejohns Certification Manager