

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB
SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

Product
Produit

Emergency Luminaires

Name and address of the applicant
Nom et adresse du demandeur

Awex Spółka z o.o. Spółka komandytowa
Masłomiaça, Długa 39
32-091 MICHAŁOWICE
Poland

Name and address of the manufacturer
Nom et adresse du fabricant

As above

Name and address of the factory
Nom et adresse de l'usine

As above

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Input 220-240V 50/60 Hz Class I or 24 VDC Class III, Plexi LED &
Escape LED IP20 & Twins IP41

Trademark (if any)
Marque de fabrique (si elle existe)

AWEX

Model / Type Ref.
Ref. De type

See pages 2 and 3

Additional information (if necessary may also be reported on page 2)

See page 3

Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2^{ème} page

A sample of the product was tested and found to be in conformity with
Un échantillon de ce produit a été essayé et a été considéré conforme à la

PUBLICATION	EDITION
IEC 60598-1:2008	7 th
IEC 60598-2-22:1997+A2:2008	3 rd

As shown in the Test Report Ref. No. which forms part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

Report number: TR/14/622 Issue 2 (8207340)

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Date: 05 September 2016
Original Issue Date 2 September 2015

Signature:



Mark Littlejohns Certification Manager

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
 CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB
 SCHEME

 SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
 D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
 METHODE OC

CB TEST CERTIFICATE
CERTIFICAT D'ESSAI OC

The type references covered by this certificate are as listed below:

Model ref.	Power	Light source/ emergency module code	Duration	Mode	Option	Cover code or colour	Assembly type
------------	-------	--	----------	------	--------	-------------------------	------------------

Self-contained

PLEXI LED PL	1W 2W 3W	LED/ B	1/2/3 Hrs	Non-maintained (SE) Maintained (SA)	X/PT/AT/ RU	WH/GR	Ceiling recessed. Exit sign
ESCAPE LED EL	1W 2W 3W	LED / B	1/2/3 Hrs	Non-maintained (SE) Maintained (SA)	X/PT/AT/ RU	WH/GR	Ceiling surface Exit sign
TWINS TW	1W 2W 3W	LED / B	1/2/3 Hrs	Non-maintained (SE) Maintained (SA)	X/PT/AT/ RU	SR/BL	Ceiling surface/ suspension/ recessed. Exit sign

Central Battery

PLEXI LED PL	1W 2W 3W	LED/ F / Z	Dependent on Power system	Central Battery (CB)	CBS/ADS/ ADP	WH/GR	Ceiling recessed. Exit sign
ESCAPE LED EL	1W 2W 3W	LED / F / Z	Dependent on Power system	Central Battery (CB)	CBS/ADS/ ADP	WH/GR	Ceiling surface Exit sign
TWINS TW	1W 2W 3W	LED / F / Z	Dependent on Power system	Central Battery (CB)	CBS/ADS/ ADP	SR/BL	Ceiling surface/ suspension/ recessed. Exit sign

 This CB Test Certificate is issued by the National Certification Body
 Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**


 BSI, Kitemark Court,
 Davy Avenue, Milton Keynes,
 MK5 8PP. United Kingdom.
 Phone +44 (0)8450 809000

 Date: 05 September 2016
 Original Issue Date 2 September 2015

Signature:



Mark Littlejohns Certification Manager

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
 CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB
 SCHEME

 SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
 D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
 METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Model ref	Power	Light source	Duration	Mode	Option	Cover code or colour	Assembly type
FZLV Central Power system							
PLEXI LED PL	1W 2W 3W	LED	Dependent on Power system	Central Power System (FZLV)	NA	WH/GR	Ceiling recessed. Exit sign
ESCAPE LED EL	1W 2W 3W	LED	Dependent on Power system	Central Power System (FZLV)	NA	WH/GR	Ceiling surface Exit sign
TWINS TW	1W 2W 3W	LED	Dependent on Power system	Central Power System (FZLV)	NA	SR/BL	Ceiling surface/ suspension/ recessed. Exit sign

Legend

PL – fixture infinity Plexi LED	PT – test button
EL – fixture infinity Escape LED	RU – rubic system UNA
TW – fixture infinity twins	NA – not applicable
AT – auto test	ADS – Central battery with ADS module ADS 20
B – code of emergency module (Uniled BM)	F – code of emergency module (Uniled HDP)
Z – code of emergency module (Uniled ADP)	ADP – central battery with electronic control gear UNILED ADP
CBS – central battery system	ADS – central battery with address moduel ADS20
WH – White, GR – Grey, BL – Black, SR - Silver	

Also tested to the requirements of:

 BS EN 60598-1:2008 + A11:2009 & EN 60598-1:2008 + A11:2009,
 BS EN 60598-2-22:1998+A2:2008 & EN 60598-2-22:1998+A2:2008.

Including European & Group differences

 This CB Test Certificate is issued by the National Certification Body
 Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**


 BSI, Kitemark Court,
 Davy Avenue, Milton Keynes,
 MK5 8PP. United Kingdom.
 Phone +44 (0)8450 809000

 Date: 05 September 2016
 Original Issue Date 2 September 2015

Signature:



Mark Littlejohns Certification Manager