

CERTIFICATE No. 104/18/Z of Conformity to European Directive

Certification program acronym – PDCWPA

Name and address of the certificate owner: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Name and address of the manufacturer: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Place of production: P.P.H.U. "AWEX" Rafał Stanuch
Masłomiąca, ul. Długa 39, 32-091 Michałowice

Product: Emergency lighting fitting OUTDOOR LED
220-240V, 50-60Hz, kl. I, IP66 according to enclosur

The product meet requirements of the Low Voltage Directive 2014/35/UE

Assessment of conformity was conducted on the basis of:

- Testing in scope of the harmonized standards:
PN-EN 60598-1:2015-04+AC:2016-02 (IDT EN 60598-1:2015/AC:2016),
PN-EN 60598-2-22:2015-01+AC1:2015-10+AC:2016-07+AC:2016-11
(IDT EN 60598-2-22:2014/AC:2015/AC:2016-05/AC:2016-09) according to the Testing Reports
No B/2018/156/1-8 of 20.07.2018 conducted by the Accredited Laboratory.
- Results of the inspection of organizational technical conditions conducted by accredited authorized and notified body for certification - according to the Report No 76/2018 of 03.07.2018.

The right to use the certificate includes the period from 31.08.2018 to 30.08.2023
and refers exclusively to products with identical properties (parameters) to the tested model and which meet requirements mentioned above.

DYREKTOR DS. CERTYFIKACJI



dr inż. Tomasz Włodek



PREZES ZARZĄDU



mgr inż. Edward Makiela

Katowice, 31.08.2018

**Enclosure
to the Certificate No. 104/18/Z
of 31.08.2018**

List of new variants of OUTDOOR LED light fittings:

CODE OF LIGHTING FITTING	POWER OF LIGHTING FITTING	CODE OF EMERGENCY MODULE	TIME OF WORK IN EMERGENCY MODE [h]	TYPE OF WORK	TYPE OF TESTING OF LIGHTING FITTING	COLOUR SYMBOL OF THE LIGHTING FITTING
ODB ODS***	3x1W	B C E	1 2 3	SE	X	GR WH BL OC
		B C	1 2 3	SA	X	
		B C E	1 2 3	SE	PT	
		B C	1 2 3	SA	PT	
		B C E*	1 2 3	SE SA	AT	
		B	1 2 3	SE SA	RS RU RW	
		F G Z**	-	-	CB CB/CBS CB/ADS CB/ADL CB/ADE CB/ADP	
		-	-	-	FZLV	

Marking of modules:

B – Uniled BM

C – Uniled BMA

E – Uniled NC

F – Uniled CB

G – Uniled CB-H

ADS – address module ADS20

ADL – address module ADL20

SE – emergency (dark)

SA – mains-emergency (bright)

AT – autotest

PT – przycisk testu

RS – Rubic system

RU – Rubic system

RW – Rubic system

CB – central battery

CBS – central battery (Awex)

FZLV – central battery 24V

ODB – lighting fitting OUTDOOR LED BIG

ODS – lighting fitting OUTDOOR LED LITTLE

GR – fixture in grey color

WH – fixture in white color

BL – fixture in black color

OC – other colors

3x1W – power of light source

* - only SE work (emergency)

** - marking Z applies only for modules ADE, ADP

*** - ODS and OS lighting fitting occurs only with central battery (CB and FZLV)


DYREKTOR DS. CERTYFIKACJI



dr inż. Tomasz Włodek



PREZES ZARZĄDU



mgr inż. Edward Makiela